

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3240-1130:141 Page 1 of 1

**CATEGORY:** Duct Detector Housing/Base

**LISTEE:** \*Honeywell International Inc., 1500 W. Dundee Road, Arlington Heights, VA 60004-1472  
Contact: Bob Hodgson (847) 797-4403 Fax (847) 797-3664

**DESIGN:** Duct smoke detector units, Models 14506873-002 and 32002812-001. Unit consists of a housing, relay, electrical components, sampling and exhaust tubes and a listed detector head.

Units are intended for use with System Sensor's Models 1451DH (CSFM Listing No. 7271-1209:126) or 2451 (CSFM Listing No. 7272-1209:131) detector heads for open area protection which have been tested for duct applications. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, air velocity rating and UL label.

**APPROVAL:** Listed as a duct detector housing when used with separately listed compatible smoke detector and control units. Intended for use in HVAC systems having air velocities between 500 to 4000 ft/min.

**XLF:** 3240-1209:155

\*Rev. 06-14-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**